



- Notes
- ©Ordnance Survey Ireland/Government of Ireland. Ordnance Survey Ireland Licence No. EN0034515.
 - All dimensions in millimetres.
 - Design for Planning Purposes, not for Construction.

Key to symbols

②	Gantry
③	Surge Arrestor
④	Cable sealing end
⑧	Overhead Line conductor
	220kV Cable sealing end compound fence (2.6m Palisade Fence)
	Property Fence (1.4m Concrete Post and Rail)
	220kV Cable
	Access Track

0 5m 10m 20m
1:200

Reference drawings

03A	02/02/2016	CT	Issued for Planning	TK	TK
02A	29/01/2016	CT	Issued for Planning	TK	TK
01A	18/12/2015	CT	Issued for Planning	TK	TK
Rev	Date	Drawn	Description	Ch'k'd	App'd

South Block
Rockfield, Dundrum
Dublin, 16
Ireland

T +353 01-2916700
F +353 01-2916747
W www.mottmac.com

Client
Apple Distribution International

Title
Caraunduff 220kV Substation
Cable Sealing End Compound Layout
Tynagh

Designed	D.McCormack	Eng check	T.Keane
Drawn	C.Thian	Coordination	D.McCormack
Dwg check	M.McCarthy	Approved	T.Keane
Scale at A1	Status	Rev	Security
1:200	APR	03A	STD
Drawing Number MMD-360988-E-DR-01-XX-9203			