



NORTH

CARAUNDUFF - CASHLA 1 220kV CABLE CIRCUIT

CARAUNDUFF - TYNAGH 220kV CABLE CIRCUIT

TOWER P3

Notes

1. ©Ordnance Survey Ireland/Government of Ireland. Ordnance Survey Ireland Licence No. EN0034515.

2. All dimensions in millimetres.

3. Design for Planning Purposes, not for Construction.

Key to symbols

2

Gantry

3

Surge Arrestor

4

Cable sealing end

7

Line Trap

8

Overhead Line conductor

220kV Cable sealing end compound fence (2.6m Palisade Fence)

Property Fence (1.4m Concrete Post and Rail)

220kV Cable

Access Track

05m10m20m

1:200

Reference drawings

03A	02/02/2016	CT	Issued for Planning	TK	TK
02A	29/01/2016	CT	Issued for Planning	TK	TK
01A	18/12/2015	CT	Issued for Planning	TK	TK
Rev	Date	Drawn	Description	Ch'k'd	App'd

Mott MacDonald

South Block  
Rockfield, Dundrum  
Dublin, 16  
Ireland

T +353 01-2916700  
F +353 01-2916747  
W www.mottmac.com

Client

Apple Distribution International

Title

Caraunduff 220kV Substation  
Cable Sealing End Compound Layout  
Prospect

Designed	D.McCormack	Eng check	T.Keane
Drawn	C.Thian	Coordination	D.McCormack
Dwg check	M.McCarthy	Approved	T.Keane
Scale at A1	Status	Rev	Security
1:200	APR	03A	STD

Drawing Number

MMD-360988-E-DR-01-XX-9204

© Mott MacDonald

This document is issued for the party which commissioned it and for specific purposes connected with the captioned project only. It should not be relied upon by any other party or used for any other purpose.  
We accept no responsibility for the consequences of this document being relied upon by any other party, or being used for any other purpose, or containing any error or omission which is due to an error or omission in data supplied to us by other parties.

P:\Dublin\MPD\360988 - Data Centre (Temp for CAD Files)\02 Temp Working Files\Planning Drawings\MMD-360988-E-DR-01-XX-9204\_03A.dwg Feb 1, 2016 - 3:33PM th73557